



ADDENDUM NO. 1 TO THE BIDDING DOCUMENTS

Fire Protection Improvements, Phase 1 Saint Clair County MidAmerica Saint Louis Airport

DATE: **May 27, 2010**

BIDS CLOSE: **June 4, 2010, at 2:30 p.m., Local Time**

TO ALL BIDDERS BIDDING ON THE ABOVE PROJECT:

The Project Manual of *Fire Protection Improvements, Phase 1, Solicitation No. 2010-03* is revised as follows. Addendum No. 1 becomes a part of the Contract Document.

I. The following are revisions to the Drawings:

1. Sheet 4, "PLAN, DETAIL AND GENERAL NOTES":

A. Add the following GENERAL NOTE number 18:

18. ALL BURIED AND EXPOSED DUTILE IRON PIPE, FITTINGS AND VALVE ACCESSORIES SUCH AS FASTENERS, NUTS AND BOLTS SHALL BE STAINLESS STEEL.

B. Add the following GENERAL NOTE number 19:

19. THE EXISTING FIRE WATER LINE IS ASSUMED TO BE AT A MAXMUM BURY OF 4.5 FT. IF IT IS DETERMINED IN THE FIELD THAT THE LINE IS DEEPER THAN 4.5 FT OR IF THE HORIZONTAL LOCATION DIFFERS GREATER THAN 10' FROM THAT LOCATION INDICATED IN THE FIELD, THE CONTRACT SUM AND TIME MAY BE EQUITABLY ADJUSTED IN ACCORDANCE WITH ARTICLE 13 OF THE AGREEMENT.

C. Add the following GENERAL NOTE number 20:

20. THE EXISTING FIRE WATER LINE SHOWN ON THIS SHEET CAN BE CLASSIFIED AS PART OF A FIRE SPRINKLER SYSTEM AND, AS SUCH, THE CONTRACTOR WORKING ON THIS SYSTEM MUST BE AN ILLINOIS LICENSED FIRE SPRINKLER CONTRACTOR CERTIFIED BY THE OFFICE OF THE STATE OF ILLINOIS FIRE MARSHAL.

2. Sheet 7, "PUMP STATION CIRCULATION PIPING - PLAN VIEW":

A. Delete reference to 8" FL. Base 90 deg bend and thrust anchor and replace it with proposed nomenclature item number 3; 8" FL 90 deg bend. The thrust anchor will not be required.

3. Sheet 8, "PUMP STATION CIRCULATION PIPING - SECTION":

A. Delete reference to 8" FL. Base 90 deg bend and thrust anchor and replace it with proposed nomenclature item number 3; 8" FL 90 deg bend. The thrust anchor will not be required.

II. Any revisions to any of the Contract Documents made by this Addendum shall be considered as the same revision to any and all related areas of the Contract Documents not specifically called out in this Addendum.



III. The Bidder shall acknowledge receipt of this Addendum by inserting the date and number in the spaces provided in the BID FORM.

MidAmerica St Louis Airport
Department of Engineering & Planning
9768 Airport Blvd, Box 3
Mascoutah, IL 62258-5500
Phone: 618.566.5321
Fax: 618.566.5324

END OF ADDENDUM NO. 1